



ਦਫਤਰ: ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ (ਭ ਤੇ ਮ) ਸ਼ਾਖਾ, ਗਿੱਦੜਬਾਹਾ  
 OFFICE: SUB DIVISIONAL ENGINEER, Provl. SUB DIVISION PWD (B&R), BR. GIDDERBAHA  
 E-mail Address: provincialsubdivngdb@gmail.com

ਸੇਵਾ ਵਿਖੇ

ਪ੍ਰਿੰਸੀਪਲ,  
 ਆਰੀਅਨ ਪਬਲਿਕ ਸਕੂਲ,  
 ਗਿੱਦੜਬਾਹਾ, ਜਿਲ੍ਹਾ ਸ੍ਰੀ ਮੁਕਤਸਰ ਸਾਹਿਬ।  
 ਨੰਬਰ: 201

ਮਿਤੀ: 03/06/25

ਵਿਸ਼ਾ: ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2025-26 ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ।  
 ਹਵਾਲਾ: ਆਪ ਦਾ ਪੱਤਰ ਨੰਬਰ ਏ.ਪੀ.ਐਸ./21/25 ਮਿਤੀ 21.05.2025 ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ ਉਸਾਰੀ ਮੰਡਲ ਗਿੱਦੜਬਾਹਾ ਜੀ ਦੇ ਪਤੇ ਤੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਆਪ ਦੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਇਸ ਦਫਤਰ ਵੱਲੋਂ ਕੀਤਾ ਗਿਆ ਅਤੇ ਪ੍ਰੋਫਾਰਮੇ ਦੇ ਕਾਲਮ ਨੰਬਰ 13 ਅਤੇ 14 ਸਬੰਧੀ ਦਫਤਰ ਫਾਇਰ ਸੇਫਟੀ ਸਟੇਸ਼ਨ, ਗਿੱਦੜਬਾਹਾ ਵੱਲੋਂ NOC No. 1602-105024-Fire/80673 Dated 03.01.2025 ਰਾਹੀਂ ਜਾਰੀ ਕੀਤੇ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੇ ਆਧਾਰ ਤੇ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸਬੰਧੀ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2025-26 (Valid upto 31.03.2026) ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ। ਇਥੇ ਇਹ ਵੀ ਸਪੱਸ਼ਟ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਇਸ ਪੱਤਰ/ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੀ ਜਗ੍ਹਾ ਦੀ ਮਲਕੀਅਤ ਨਾਲ ਕੋਈ ਸਬੰਧੀ ਨਹੀਂ ਹੈ।

(ਵਿਸ਼ੇਸ਼ ਕਥਨ ਇਹ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਵੱਲੋਂ ਨੱਥੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਰਿਨੀਊਲ ਪ੍ਰਤੀਬੇਨਤੀ ਨੰਬਰ 1602-105024-Fire/80673 Dated 03.01.2025 ਦੇ ਆਧਾਰ ਤੇ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ। ਇੱਥੇ ਦੱਸਣਯੋਗ ਹੈ ਕਿ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਨੂੰ ਰੀਨਿਊ ਕਰਵਾਉਣਾ ਲਾਜ਼ਮੀ ਹੈ ਅਤੇ ਨਵਾਂ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਹੋਣ ਉਪਰੰਤ ਇਸ ਦਫਤਰ ਨੂੰ ਭੇਜਿਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ। ਅਜਿਹਾ ਨਾ ਕਰਨ ਦੀ ਸੂਰਤ ਵਿੱਚ ਆਪ ਨੂੰ ਜਾਰੀ ਕੀਤਾ ਗਇਆ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਮੰਨਿਆ ਜਾਵੇਗਾ।)

ਨੋਟ:- ਸਾਲ 2026-2027 ਲਈ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦਾ ਕੇਸ ਮਿਤੀ 01.04.2026 ਤੋਂ ਪਹਿਲਾਂ ਪਹਿਲਾਂ ਅਪਲਾਈ ਕਰਨਾ ਸਕੂਲ ਮੁੱਖੀ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਹੋਵੇਗੀ।

ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ।

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,

ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ. (ਭ ਤੇ ਮ) ਸ਼ਾਖਾ,  
 ਗਿੱਦੜਬਾਹਾ।

ਮਿਤੀ

ਪਿੱਠ ਅਕੰਣ ਨੰਬਰ

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਗਿੱਦੜਬਾਹਾ ਜੀ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪੱਤਰ ਨੰਬਰ 2802-05 ਮਿਤੀ 02.12.2024 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ ਜੀ।

ਨੱਥੀ/ਫਾਇਲ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,

ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ. (ਭ ਤੇ ਮ) ਸ਼ਾਖਾ,  
 ਗਿੱਦੜਬਾਹਾ।

# FORMA FOR THE SAFETY OF SCHOOL BUILDING PART-I (To be filled by the Head of School / Institute)

1. Name of the School : Aryan Public School, Gidderbaha
2. Location : Ward No-6
3. Plot Area : 13340 sq feet
4. Plinth Area : 9810 sq feet
5. Number of Storeys : Two
6. Year of Construction of Building : 1994
7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given :- : Yes
  - a) Name of the Engineer with qualification : Mr. Ajit Sharma
  - b) Address of Engineer : Near Bus stand
  - c) Set of structural drawings used in the construction, if available : Gidderbaha
  - d) Name & Address of architect with qualification :
8. Whether the building has been constructed for the purpose. :
  - a) School : ☒ Yes / ☐ No
  - b) Residential Purpose and converted for use as a School. : ☒ Yes / ☐ No
9. Materials used for roofs :
  - a) R.C.C. Slabs / R.B.C. Slabs. : ☒ Yes / ☐ No
  - b) R.S. Joists & Battons. : ☒ Yes / ☐ No
  - c) Wooden joists & Battons. : ☒ Yes / ☐ No
10. Materials used for walls. :
  - a) Mud Mortar. : ☒ Yes / ☐ No
  - b) Cement Mortar. : ☒ Yes / ☐ No
  - c) Lime Mortar. : ☒ Yes / ☐ No
11. Flooring. :
  - a) Conglomerate. : ☒ Yes / ☐ No
  - b) Terrazo. : ☒ Yes / ☐ No
  - c) Brick Paving. : ☒ Yes / ☐ No
12. A details drawing indicating dimensions of the rooms alongwith size and location of doors and windows.(Attached) : ☒ Yes / ☐ No
13. FOR FIRE SAFETY. :
  - a) Weather the width of the staircase is 1.5 mtr. : ☒ Yes / ☐ No
  - b) Weather portable fire extinguisher exists. : ☒ Yes / ☐ No
  - c) Weather School building is free from inflamable & toxic material : ☒ Yes / ☐ No

*(Signature)*  
Principal

Aryan Public School  
Gidderbaha

(Contd...2..)

- d) Weather cooking of food is done at a safe place. : Yes / No
- e) Weather any Thatch combustible material has been used. : Yes / No
14. Requirement for Fire Protection Arrangements under NBC-  
Part-IV : Yes / No  
(For Building height less than 15 metre)
- a) Weather Hose Real provided. : Yes / No
- b) Weather down comer provided. : Yes / No
- c) Weather Automatic sprinkler provided. : Yes / No
- d) Weather underground static water storage tank of capacity  
50,000 Ltr. (if covered area exceeds 1500 sqm.) : Yes / No
- e) Weather over Head tank of capacity 10,000 Ltr. Exists (in case  
of hose real) 20,000 Ltr. : Yes / No
- f) Weather one electric and one deisel pump of capacity pressure  
of capacity 1620 LPM exist near underground static tank. : Yes / No
- g) Weather a pump 3 kg/ cum pressure & 450 / 500 LPM exist  
near over head tank. : Yes / No

*[Signature]*  
Principal

Aryan Public School  
Gidderbaha

Signature with Stamp of the seal  
of the School / Institution.

checked and found safe.  
*[Signature]*

## PART-II

(To be filled by the S.D.E. of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated 03-06-2025 And have  
visually inspected it from safety and find it fit for normal use as school buildings.
- b) In case any addition / alteration or expansion and modifications to this buildings is to be  
carried out, the same be carried out under the supervision of a qualified Engineer and this  
certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if these is settlement of walls / foundations or  
sagging or roofs etc. immediate inspection of the undersigned be arranged to check the  
stability and safety of the building.
- d) This building can be safety occupied for normal use upto (indicate upto which it can be  
used) 31-03-2026 but due to non-renewal of fire safety certificate by  
school/institute this building safety certificate will be invalid after 03-01-2026

Counter Signed

Executive Engineer,  
Constn. Divn. PWD (B&R) Br.  
Gidderbaha.

*[Signature]*  
Sub Divisional Engineer, Sub Divisional Engineer,  
Prov. Sub Divn. PWD B&R PWD (B&R) Br.  
Gidderbaha

*[Signature]*



(Translation from Punjabi into English)

Logo Govt. of Punjab.

Office:- Sub Divisional Engineer, Provl. Sub Division PWD (B&R) Br. Gidderbaha  
E-mail Address: provincialsubdivngdb@gmail.com

**MUNICIPAL COUNCIL, GIDDERBAHA**  
**Distt. Sri Muktsar Sahib.**

To

Principal,  
Aryan Public School,  
Gidderbaha, Distt. Sri Muktsar Sahib.

No. 201

Date: 03-06-25

Subject:- Regarding the issue of School Building Safety Certificate for the year 2025-26.

Reference: Your letter No. A.P.S./21/25 dated 21.05.2025 to the address of Executive Engineer Construction Division, Gidderbaha.

In connection with the above subject and reference letter, the inspection of your shcool building was carried out by the office and on the basis of the Fire Safety Certificate issued by the Fire Safety Station, Gidderbaha through NOC No. 1602 105024-Fire/ 80673 Dated 03-01-2025 in respect of columns 13 and 14 of the proforma, the safety certificate for the shcool building is issued for the year 2025-26 (Valid upto 31,03,2026). It is also clarified that this letter/safety certificate has no connection with the ownership of the school premises.

(Remarks) This building safety certificate has been issued on the basis of the attached Fire Safety Certificate renewal request No. 1602-105024-Fire/80673 Dated 03-01-2025. It is worth mentioning that it is mandatory to get the Fire Safety Certificate renewed and ensure that the new Fire Safety Certificate is sent to this office after it is issued. Failure to do so will rendere the Safety Certificate issued to you void.

Note:- The case of building certificate for the year 2026-2027 the case date apply before 01-04-2026, it will be the responsibility of the school head.

Sd/-  
Sub Division Engineer,  
Provl. Sub Division,  
PWD (B&R) Branch  
Gidderebaha.

Endorsement No.

Date:

A copy of above is forwarded to Executive Engineer, Construction Division, B & R Branch, Gidderbaha in reference to their letter No. 2802-05 Dated 02.12.2004 Sub Divisional Engineer, B & R Branch Gidderbaha for information.

Translation Punjabi to English

ATTESTED

Angrej Singh Mann Advocate  
Notray Public, Gidderbaha

Sd/-  
Sub Division Engineer,  
Provl. Sub Division,  
PWD (B&R) Branch  
Gidderebaha.

